



Government of West Bengal
Office of the Divisional Fire Officer
West Bengal Fire & Emergency Services
Bhangakhuti, Purba Burdwan, P.O.- Rajbati, Pin :- 713104

Memo No.: FSR/IND/WB/FES/20192020/74940.

Date : 28-09-2026

From :
Divisional Fire Officer
Purba Bardhaman Division,
West Bengal Fire & Emergency Services

To :
Delhi Public School
Vill and Mouza- Belgram, R S Plot No- 2143,2145,2151,2154, Kh No- 1612,1614,1615, J.L No- 117, P.S- Galsi, Dist -
Purba Bardhaman, Pin- 713141.

Sub : Renewal of Fire Safety Certificate for an Existing construction of G+III storied building under group Educational Occupancy, in the name and style as "DELHI PUBLIC SCHOOL" situated within Vill & Mouza-Belgram, Plot No-2143,2145,2147,2151, Kh No-1612,1614,1615 JL No-117 PO-Belgram, PS-Galsi, Dist.-Purba Bardhaman, Pin- 713141 (WB).

This is in reference to your AIN 211912606300012994 dated 12-Aug-2026 regarding Renewal of Fire Safety Certificate for an Existing construction of G+III storied building under group Educational Occupancy, in the name and style as "DELHI PUBLIC SCHOOL" situated within Vill & Mouza-Belgram, Plot No-2143,2145,2147,2151, Kh No-1612,1614,1615 JL No-117 PO-Belgram, PS-Galsi, Dist.-Purba Bardhaman, Pin- 713141 (WB)..

The performance of the Fire Fighting System as incorporated in the building were tested at random and found satisfactorily working condition. In view of the above this office is releasing the **Renewal of Fire Safety Certificate** for occupancy of the aforesaid building.

However to up-keep the Fire Safety Measure of the aforesaid building the following safety measures need to be incorporated maintained.

Recommendation:

1. All the Fire Safety measures provided in the building must be kept in good working condition all the time to ensure fire & life safety of the building.



The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300012994

2. Driveway must be free from any type of obstruction for easy movement of Fire Appliances. No parking will be allowed on the Drive way.
3. The Interior finish decoration of buildings shall be made with low flame spread material confirming to the I.S. Specification.
4. To eliminate risk of Fire Hazards, Good House Keeping both for insides and outside of the buildings shall be strictly maintained.
5. Existing Electrical wiring of the whole buildings shall have to be carefully checked for any wear and tear in them, particularly lines above false ceiling & ducts.
6. A Fire control room including a closed-circuit TV system shall have to be maintained which observe all the floors of the building.
7. The notice of Fire Fighting and Evacuation from the buildings shall be prepared and displayed at all vulnerable places of the buildings.
8. The employees and security staff shall be conversant with installed firefighting equipment of the buildings and to operate in the event of fire and testing.
9. Mock Fire practice and evacuation drill shall be performed periodically with participants of all the occupants of the buildings.
10. A trained Fireman shall be maintained round the clock for fire safety of the building.
11. First Aid firefighting system shall be provided as per I.S. specifications.
12. Arrangement shall have to be made for regular checking, testing, and maintenance of all The Fire Fighting installation in the buildings to keep them in perfectly good working Condition at all the times.
13. The Fire Safety audit to be conducted at regular interval and to be recorded in the Fire Prevention maintenance registers.
14. Electrical Ducts shall have to be sealed vertically and horizontally in proper manner immediately.
15. The Fire Safety Certificate is valid for a period of three (3) years from the date of issue. And has to be renewed after three years certifying about the satisfactory services, performance of all the Life Safety arrangements installation of the building.
16. Any deviation and changes the nature of use of the building in respect of the approved plan drawing, without obtaining prior permission from this office, this Fire Safety Certificate will be treated as cancelled.

Valid Upto : 26-Sep-2029

Memo No.:
FSR/IND/WB/FES/20192020/74940.

Sheli Ghosh Banerjee
Principal
DELHI PUBLIC SCHOOL
BURDWAN



Rajesh Bhagat
MANAGER
DELHI PUBLIC SCHOOL
BURDWAN



Signature Not Verified

Digitally Signed.
Name: SUMIT SUR
Date: 28-Sep-2026 15:00:56
Reason: D-Sign
Location: E-Dist 2.0

Divisional Fire Officer

West Bengal Fire & Emergency Services

The authenticity of this document can be verified by accessing the URL: edistrict.wb.gov.in and then clicking on the Verification of Digitally Signed Document link and keying in the Unique Number : 211912606300012994